

# GSH Güteschutzgemeinschaft Hartschaum e.V.

## ATTESTATION OF CONFORMITY

We herewith attest that the building products

### Polystyrene – Rigid Foam Thermal Insulation Boards

- 1.) Peripor EPS 200
- 2.) Peripor EPS 250

with the designation code

- 1.) EPS – EN 13163 – T(1) – L(2) – W(2) – S(2) – P(5) – DS(N)2 – DS(70,-)1 – BS250 – CS(10)200 – WL(T)1
- 2.) EPS – EN 13163 – T(1) – L(2) – W(2) – S(2) – P(5) – DS(N)2 – DS(70,-)1 – BS350 – CS(10)250 – WL(T)1

1 and 2) Reaction to fire: Euroclass E  
Declared thermal conductivity,  $\lambda_D = 0,033 \text{ W/(m}\cdot\text{K)}$


from the manufacturer

**RIZAKOS S. A.**  
**Lamia Industrial Estate**  
**GR-35100 Lamia**  
**GREECE**

based on the  
**Product Type Determination (former ITT)**  
and the continuous surveillance and evaluation of the  
**Factory Production Control (FPC)**  
comply with the requirements of  
**EN 13163:2012+A1:2015.**

The manufacturer RIZAKOS S.A. is authorized to bear the CE-mark on the above mentioned product. This attestation is valid until **30.11.2021**. The validity can be prolonged by seal of the GSH and signature of the manager of the certification body.

19.11.2020 / 09 12 017-1.e-R8

  
Manager of the Certification Body  
Corth Siegfried

Prolonged until: **31 Okt. 2022**



Prolonged until:



Schildenstraße 24  
D-29221 Celle  
Notified Body 0919  
UZ: UG 049

Tel +49 (0)5141-88 92 65  
Fax +49 (0)5141-88 92 67  
www.gsh.eu  
info@gsh.eu